



THIS DRAWING HAS BEEN PRODUCED FOR DISCUSSION / DESIGN DEVELOPMENT PURPOSES ONLY

- NOTES:**
- CABLE TO MAINTAIN MINIMUM 15M FROM TOWER FOUNDATIONS AND MINIMUM 2M FROM FENCE
  - ALL WORK WITHIN A NOMINAL HORIZONTAL DISTANCE OF 15M OF THE TRANSMISSION OVERHEAD LINE OUTERMOST CONDUCTOR, AS MEASURED AWAY FROM THE OUTERMOST CONDUCTOR SHOULD BE LIMITED TO A MAXIMUM SAFE WORKING HEIGHT FROM GROUND LEVEL. PLEASE REFER AND ADHERE TO THE SAFE WORKING GUIDANCE IN G56
  - CONTRACTOR TO FOLLOW PHASE SEQUENCE THROUGHOUT INSTALLATION. NO TRANSPORTATION OF POWER CABLES IS ANTICIPATED TO BE REQUIRED.
  - ECC DUCTS TRANSPPOSED AT THE MID POINT OF THE SINGLE POINT SECTION AS INDICATED

- LEGEND:-**
- GRESHAM HOUSE
  - BERWICK BANK
  - EGL HV-AC
  - BRANXTON PV & BES
  - LAWFIELD
  - EGL HV-DC
  - TORNESS
  - BATTERY STORAGE
  - THORNTON BRIDGE

DA	06/10/2023	JAM	ACM	BT	FIRST ISSUE FOR TENDER
Rev	Date	Drawn	Reviewed	Approved	Reason/Description of changes
					Project: BRANXTON (TORI 124) Location: BRANXTON SOUTH Dwg Title: OVERALL CABLE ROUTE
					Drawn: [ ] Rev'd: [ ] App'd: [ ] File No: CTXXXX-1-0X00-DR-XXXX-0X00 Scale: 1:60000 Sheet: 1 of 0A Date: 06/10/2023